

### Summary of ET Leader's Site Environmental Audit in the Reporting Month

Parameters	Date	Observations and Recommendations	Follow-up
Air Quality	14 Feb 2023	Observation 1: Fugitive dust is observed at TTS area. Provide mitigation measure e.g. increase water spraying for dust suppression at TTS area (Portion 1 - YLSTW).	28 Feb 2023
	21 Feb 2023	Reminder 1: The Contractor is reminded to increase watering for dust suppression at TTS area (Portion 1 - YLSTW).	28 Feb 2023
Noise	NA		
Water Quality	NA		
Chemical and Waste Management	1 Feb 2023	Reminder 1: The Contractor is reminded to provide drip tray for the chemical containers. (Portion 1 - YLSTW).	2 Feb 2023
Land Contamination	NA		
Ecological Impact	NA		
Landscape and Visual Impact	21 Feb 2023	Recommendation 1: Crown cleaning to remove broken and hanging branches at east side of TTS (Portion 1 - YLSTW).	28 Feb 2023
	28 Feb 2023	Recommendation 1: Please observe proper pruning procedures to avoid causing damages to the branches to be pruned (Portion 1 - YLSTW).	28 Feb 2023
Permit / Licenses	NA		
Others	NA		