

### Summary of ET Leader's Site Environmental Audit in the Reporting Month

Parameters	Date	Observations and Recommendations	Follow-up
Air Quality	6 Apr 2022	Recommendation 1: The Contractor is recommended to provide water spraying to prevent dust emission for access road at FST Area (Portion 1 - YLSTW).	6 Apr 2022
	12 Apr 2022	Reminder 1: The Contractor is reminded to provide water spraying for dust suppression at haul roads (Portion 1 - YLSTW).	12 Apr 2022
Noise	NA		
Water Quality	NA		
Chemical and Waste Management	20 Apr 2022	Reminder 1: The Contractor is reminded to clean up the oil stain on road with chemical absorbent pad and treat it as chemical waste for disposal (Portion 1 - YLSTW).	20 Apr 2022
Land Contamination	NA		
Ecological Impact	NA		
Landscape and Visual Impact	27 Apr 2022	Reminder 1 (Landscape & Visual Impact): Please keep adjacent ground of trees free of construction materials (Portion 1 - YLSTW).	27 Apr 2022
Permit / Licenses	NA		
Others	NA		